



CITY OF PATNA
पटना नगर निगम, पटना

कार्यपालक अभियंता, PIU-01 का कार्यालय
मौर्याटावर, प्रथम तल, कमरा नं.-6, बुद्धमार्ग, पटना-800 001
अति अल्पकालिन कोटेशन आमंत्रण सूचना
कोटेशन आमंत्रण सूचना सं0-01, वर्ष-2020-2021

पटना नगर निगम, मौर्यालोक कॉम्पलेक्स अन्तर्गत ब्लॉक-सी. के चौथी एवं दूसरी तल पर Fire Hydrant System लगाने हेतु सामाग्रियों के दर के कोटेशन, कोटेशनदाता से दिनांक-04.08.2020 को अपराह्न 3:00 बजे तक कोटेशन आमंत्रित किया जाता है। सभी सामाग्रियों का दर सामाग्रियों को स्थल पर पहुँचाने, लगाने, पेंट करने, लगाने के बाद जाँच करने इत्यादि के साथ होगा। कोटेशनदाता को PAN एवं GST की अभिप्रमाणित छायाप्रति कोटेशन के साथ संलग्न कर बंद लिफाफा में जमा करना अनिवार्य होगा। सभी प्राप्त कोटेशन को उसी तिथि को अपराह्न 4:00 बजे मुख्य नगर अभियंता के कार्यालय कक्ष में खोला जायेगा।

उक्त कार्य के बारे में विस्तृत जानकारी एवं अन्य सूचना किसी भी कार्य दिवस में अद्योहस्ताक्षरी के कार्यालय या वेबसाइट pmc.bihar.gov.in पर देखा जा सकता है।



Sr.No.	Items	Rate
1	MS Pipe 100 MM (Tata)	
2	MS Pipe 80 MM (Tata)	
3	Single Outlet Oblique type Landing Valve in 63 mm dia with 3" NB flanged with female instantaneous coupling made of Stainless Steel with Cast Iron Hand wheel having Hydrostatic Test (Body Test) tested at 21kgf/cm2 , Water Tightness (Seat Test) at 14kgf/cm2 & Flow Test 900 LPM discharge at 7kgf/cm2 complete with ISI marked IS: 5290	
4	Fire Hose Box double door made in 22/24 gauge to accommodate 1 nos of Fire Hose of 30 meter length with one Short Branch nozzle having glass front & locking arrangement.	
5	(Reinforced Rubber Lined) Hose 63 mm dia in 30 Mtr length made of circular woven jacket treated with rot proofing agent with rubber inner lining for flexibility, durability & better resistance complete with ISI marked IS: 636: 1988 Type - A	
6	Male & Female Instantaneous type Coupling in 63 mm dia Made of Stainless Steel having the Hydrostatic Test (Body Test) of 21kgf/cm2 complete with ISI marked IS:903	

7	Short Branch Pipe in 63 mm dia with nozzle of 20 mm made of Stainless Steel having the Hydrostatic Test (Body Test) of 21kgf/cm2 complete with ISI marked IS: 903.	
8	First Aid Hose Reel Drum with wall mounted swinging type with ISI marked IS: 884:1985	
9	General Purpose Rubber Water Hose in 3/4" dia in 30 Mtr Length made of Uniform seamless lining of natural or blend of natural & synthetic rubber with reinforcement plies of woven fabric or braided textile of high strength complete with ISI marked IS: 444	
10	Brass Nozel (Hose Real Pipe)	
11	Double Outlet Landing Valve in 63 mm dia with 4" NB flanged with female instantaneous coupling made of Gun Metal / Stainless Steel / Aluminium with Cast Iron Hand wheel having Hydrostatic Test (Body Test) tested at 21kgf/cm2 , Water Tightness (Seat Test) at 14 kgf/cm2 & Flow Test 1800 LPM discharge at 7 kgf/cm2 complete with ISI marked IS: 5290	
12	Air Release Valves	
13	Butterfly Valve: 100 MM	
14	NRV: 100 MM	
15	Ball Valve 25MM	
16	Hose Real Fitting	
17	Flanch	
18	Band	
19	MS Pipe 80 MM (Tata)	
20	MS Pipe 50 MM (Tata)	
21	MS Pipe 20 MM (Tata)	
22	Sprinklers	
23	Tide Rod	
24	Butterfly Valve: 80 MM	
25	NRV: 80 MM	
26	Jocky Pump capacity 180 LPM at 60Mtr Head	
27	Water Tank (5000 Ltr)	
28	Smoke Detector	
29	Fire Alarm Pannel	
30	MCP	
31	Hooter	
32	Copper wire of 2.5mm in m	
33	ABC MAP in Kg	
34	CO2 4.50 kg cylinder	
35	Clean Agent in kg	
36	Signages	

विश्वासभाजन

SPC
23/07/2022

कार्यपालक अभियंता,

PIU-01

पटना नगर निगम।